

Emission Test Certificate

Monday, 23th October 2017

Supplier: Bishop Decorative Finishes (27 Jessie Street, Richmond Vic 3121).

Sample Description: Water Stone Polished Plaster

Date Tested: September 2017 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D5116 “Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products”.

Emission Data (7 days):

<p>Green Building Council of Australia Green Star Interiors v1.1 – 12.1.2B Green Star Office Design v1.1 – 13.1.2B</p>	<p>Water Stone Polished Plaster</p>
<p>Total Volatile Organic Compound Emission Rate limit: <0.5 mg/m²/hr</p>	<p>Total Volatile Organic Compound Emission Rate: 0.083 mg/m²/hr</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Nick Joy
BSc(Hons)
Consultant



Tuan Duong
B Eng. (Chem.)
Consultant

CV170918